



Cite as
Nano-Micro Lett.
(2023) 15:85

Received: 30 December 2022
Accepted: 23 February 2023
Published online: 31 March 2023
© The Author(s) 2023


Screen-Printable Functional Nanomaterials for Flexible and Wearable Single-Enzyme-Based Energy-Harvesting and Self-Powered Biosensing Devices

Kornautchaya Veenuttranon¹, Kanyawee Kaewpradub^{1,2}, Itthipon Jeerapan^{1,2,3}

HIGHLIGHTS

- Screen-printable functional nanocomposite inks are engineered for flexible, single-enzyme-based energy-harvesting, and self-powered biosensing devices.
- A BFC powered by the same biosubstrate (glucose) is developed to harvest energy in a biofluid model and act as a self-powered electrochemical glucose.
- Customized inks are advantageous in terms of integrating with flexible materials, which can be integrated with a wide range of wearables and soft bioelectronics.

ABSTRACT Developing flexible bioelectronics is essential to the realization of artificial intelligence devices and biomedical applications, such as wearables, but their potential is limited by sustainable energy supply. An enzymatic biofuel cell (BFC) is promising for power supply, but its use is limited by the challenges of incorporating multiple enzymes and rigid platforms. This paper shows the first example of screen-printable nanocomposite inks engineered for a single-enzyme-based energy-harvesting device and a self-powered biosensor driven by glucose on bioanode and biocathode. The anode ink is modified with naphthoquinone and multiwalled carbon nanotubes (MWCNTs), whereas the cathode ink is modified with Prussian blue/MWCNT hybrid before immobilizing with glucose oxidase. The flexible bioanode and the biocathode consume glucose. This BFC yields an open circuit voltage of 0.45 V and a maximum power density of $266 \mu\text{W cm}^{-2}$. The wearable device coupled with a wireless portable system can convert chemical energy into electric energy and detect glucose in artificial sweat. The self-powered sensor can detect glucose concentrations up to 10 mM. Common interfering substances, including lactate, uric acid, ascorbic acid, and creatinine, have no effect on this self-powered biosensor. Additionally, the device can endure multiple mechanical deformations. New advances in ink development and flexible platforms enable a wide range of applications, including on-body electronics, self-sustainable applications, and smart fabrics.



✉ Itthipon Jeerapan, itthipon.j@psu.ac.th

¹ Center of Excellence for Trace Analysis and Biosensor, Prince of Songkla University, Hat Yai, Songkhla 90110, Thailand

² Division of Physical Science, Faculty of Science, Prince of Songkla University, Hat Yai, Songkhla 90110, Thailand

³ Center of Excellence for Innovation in Chemistry, Faculty of Science, Prince of Songkla University, Hat Yai, Songkhla 90110, Thailand



KEYWORDS Screen-printable nanocomposites; Glucose; Glucose oxidase; Biofuel cells; Self-powered biosensors; Flexible bioelectronics

1 Introduction

Flexible bioelectronics have many useful and versatile applications, such as wearables [1]. Unlike rigid, traditional platforms, a flexible device offers a unique opportunity to match the curvature of soft surfaces. For instance, modern on-body electronics, such as smart fabrics for tracking motion and monitoring biochemicals, are rapidly expanding. Soft robots and humanoid robots also benefit from flexible systems. Smart flexible devices open new opportunities for continuous fitness monitoring and are revolutionizing health care by enabling wellness monitoring. Regardless of the application, these devices should be fully integrated, lightweight, flexible, and autonomous from both a practical and esthetic perspective. To achieve the desired functions, it is necessary to develop several strategies. Further decreasing device size and fabrication costs are among them. To achieve this, incorporating customized materials and engineering ideas into a new design of flexible bioelectronics is essential.

A key barrier to the advancement of fully integrated flexible devices is the lack of energy. To overcome the energy requirements of soft devices, a common approach is to enhance the volumetric capacity and power density of flexible energy storage devices [2]. However, traditional systems still use rigid batteries without a self-charging technique; therefore, they must be periodically charged or replaced [3]. In addition to energy-storage systems, there is a growing interest in energy-harvesting technologies that convert surrounding energy (e.g., biomechanical, biochemical, and solar energy) into electricity. Motivated by the desire to realize the energy-sustainable concept, enzymatic biofuel cells (BFCs), which convert biochemical energy available in human biofluids into electricity, are among the most powerful alternatives for energy generation. This is due to their advantages for operation with enzymes that are active at ambient temperature and under mild physiological conditions, allowing on-body, implantable, and ingestible applications in biological systems [4–6].

Significantly, in addition to being energy-conversion devices, BFCs can also be used as self-powered electrochemical biosensors to sense analytes without external power [4]. Since the generated power is typically proportionate

to the analyte concentration, BFCs can monitor the level of a specific substrate in real time as a stand-alone device. Enzymatic BFCs use enzymes (e.g., glucose oxidase (GOx)) as biocatalysts to convert the chemical energy of biofuels (e.g., glucose) in a body fluid into electrical energy. Thanks to the high selectivity of enzymes, it is not necessary to separate the anodic and cathodic counterparts, enabling the straightforward design of a two-electrode system that could be further developed into practical miniaturized devices. As of now, self-powered BFCs have been successfully used to detect a variety of chemicals, such as glucose [7], cholesterol [8], and lactate [9].

Even though substantial advances have been made in developing BFC-based energy harvesters or self-powered biosensors, most current technologies use BFCs with a two-enzyme configuration (using different enzymes on a bioanode and a biocathode). The development of bi-enzymatic BFCs faces critical challenges. First, different enzymes require different operating conditions, such as pH. There is a significant difference between laboratory applications using gold-standard setups with separation membranes and chambers and real-world applications. Managing pH is too challenging for wearable devices and miniaturized devices; it is hard to control one pH for the wearable anode while adjusting the other pH value for the cathode. Those factors can affect the BFC performance. In addition, the use of two enzymes complicates the BFC design and increases its cost. For example, GOx costs only 0.4 USD per 100 units, whereas laccase and bilirubin oxidase cost much more (30–700 USD per 100 units). Hence, we aim to address such grand challenges by engineering new BFCs with only one enzyme on the anode and the cathode.

Despite the advantages of wearable BFCs and the single-enzyme-BFC configuration, no reports exist today to demonstrate a single-enzyme BFC and self-powered biosensors on any flexible or printed platforms (Table S1). Previously, a BFC powered by the glucose for both the bioanode and the biocathode, yielding the maximum power of $3.5 \mu\text{W cm}^{-2}$, was illustrated [10]. On this bioanode, GOx was immobilized on a modified graphite rod electrode. In fact, GOx was co-immobilized with an additional enzyme, i.e., horseradish peroxidase (HRP) on the

rigid cathode. Note that the extra cost due to HRP (~13 USD per 100 unit) would increase the fabrication cost. Another BFC on rigid graphite rods was reported [7]. Both the bioanode and the biocathode were immobilized with the same enzyme (i.e., GOx), while the BFCs operated by GOx oxidation at the bioanode and H_2O_2 reduction at the biocathode. The power output of the system obtained only $10.9 \mu\text{W cm}^{-2}$. Notably, these BFC designs are limited by the use of rigid platforms, that are hard to integrate into biosystems. To the best of our knowledge there are no publications on any flexible single-enzyme BFCs that demonstrate the applicability in simulated biological fluids.

This paper presents the first example of screen-printable functional inks engineered for a flexible single-enzyme-based energy-harvesting device and a self-powered bio-sensor, which use only glucose on the bioanode and biocathode (Fig. 1). We developed new printable and highly flexible inks for both the anode and the cathode. In addition to demonstrating a single-enzyme-based BFC design, a key novelty of the present work is the customized formulations of nanocomposites. These nanocomposites have high conductivity and can adhere to a range of versatile substrates, including stretchable textile, plastic, stretchable epidermal tattoo, and rubber-based materials. The reactions occurring




Fig. 1 The conceptual presentation of a screen-printed and flexible single-enzyme-based system for harvesting energy from glucose and self-powered sensing glucose. **a** The components of a screen-printed glucose BFC along with redox reactions occurring on the bioanode and the biocathode. **b** Preparation of the screen-printable inks for the anode and the cathode. **c** Photographs of a screen-printed glucose BFC on (1) PET, (2) a stretchable textile (arm sleeve), (3) a glove (fingertip), and (4) a stretchable epidermal tattoo attached to a hand model. **d** The working operation of a screen-printed glucose BFC on (top and bottom) energy-harvesting and self-powered sensing modes

on the BFCs were driven by the same biofuel (glucose) for both the bioanode and the biocathode by employing the same biocatalyst (GOx) immobilized on the surface of both electrodes (Fig. 1a). At the bioanode, the electrocatalytic reaction involves glucose oxidation. This results from electron transfer between the GOx active site and 1,4-naphthoquinone (NQ)-mediated nanocomposite. At the biocathode that uses glucose to produce hydrogen peroxide (H_2O_2), the reaction is based on H_2O_2 reduction, aided by Prussian blue (PB) as an electrocatalyst. Thus, the combination of such oxidation and reduction reactions allows the formation of a single-enzyme-based device to harvest energy from glucose and act as a self-powered glucose biosensor. The successful application of these screen-printed BFCs to human sweat model suggests their potential as flexible, energy-sustaining, and noninvasive glucose monitoring devices.

2 Experimental Section

To demonstrate the concept of self-powered BFC, a screen-printed GOx/NQ/MWCNT-based bioanode and a screen-printed GOx/PB/MWCNT-based biocathode were prepared, followed by morphology study, electrode characterization, resistance, and electrochemical measurement. The BFC characterization and self-powered detection were performed, followed by an application study such as selectivity and operational stability. Mechanical resiliency was investigated (see the Supporting Information for details). The chemicals, reagents and artificial sweat used in this study are also described in the Supporting Information.

3 Results and Discussion

3.1 Concept of a Screen-Printed Glucose BFC

The operation of our single-enzyme BFC is based on glucose oxidation catalyzed by GOx at the bioanode and H_2O_2 reduction catalyzed by PB-based nanocomposites at the biocathode (Fig. 1). Glucose was chosen as a model for both compartments because it is one of the most suitable biological substrates, commonly found in various biofluids, such as blood, tears, sweat, saliva, and interstitial fluids [11]. Our BFC converts glucose (a biological fuel) into electrical energy; this energy-conversion technology is different from conventional fuel cells, such as H_2/O_2 and methanol/ O_2 fuel

cells, as they can operate under mild conditions, such as in physiological media and at ambient temperatures [4]. Additionally, a membrane is often required to separate anode and cathode compartments. The use of an enzymes (biocatalyst) in this work enables a membraneless BFC design due to the selectivity toward the specific biofuel. This meets our objective of simplifying BFC configurations.

At the bioanode, the oxidation reaction occurs when glucose interacts with the active site of GOx, resulting in electron transfer toward the printed nanocomposite-based electrode through NQ (a redox mediator) (Fig. 1a). These harvested electrons due to the glucose oxidation flow toward the load and the biocathode, completing the electrical circuit. Meanwhile, glucose is also used on the biocathode. First, GOx enzymatic reaction generates H_2O_2 . This H_2O_2 along with gluconolactone are formed when glucose molecules reach the GOx immobilized on the biocathode in the presence of oxygen. The biocathode reaction is then based on H_2O_2 reduction with the help of printed PB-based nanomaterials as an electrocatalyst. Challengingly, when using a conventional electrode, H_2O_2 can be reduced only at a high overpotential [12]. Therefore, it is required to engineer nanocatalytic materials to decrease the overpotential of H_2O_2 cathodic reaction on the flexible biocathode.

Regarding the BFC fabrication, we engineered new screen-printable functional inks for supporting both the anode and the cathode to fabricate a highly flexible energy-harvesting device and a self-powered biosensor (Fig. 1b). We leveraged a screen-printing technique to fabricate the flexible electrodes because this technique is simple, high-throughput, scalable, and low-cost and can be applied to a wide range of substrate materials [13]. Importantly, inks can be modified to combine additional functions, such as electrochemical catalytic activities. Different inks and substrates can be used to create custom electrodes. To formulate highly flexible and homogeneous inks, chemical interactions between the added materials and mechanical force must be employed to aid in their preparation.

To improve the performance of the BFCs, it is necessary to add materials with extra functions to the ink recipes. The anode ink contains graphite and MWCNTs (as conductive fillers), NQ (as a redox mediator), and polyurethane (PU, as a polymeric binder) dispersed in an organic solvent (Fig. 1b, left). On the other side, the cathode ink comprises of graphite, a PB/MWCNT hybrid nanomaterial (as an electrocatalyst), and PU dispersed in tetrahydrofuran (THF) (Fig. 1b,

right). Graphite and MWCNTs were used in both electrodes due to their good conductivity and stability [14, 15]. These inks contain graphite with a particle size less than 20 μm and MWCNTs with an aspect ratio of ~ 700 –6000. These MWCNTs with a long tubular structure have a high specific surface area, allowing stable accommodation for GOx and NQ mediator molecules. NQ integrated in the MWCNTs matrix was used as redox mediator to shuttle electrons from the glucose oxidation at the mediated bioanode to enhance catalytic current densities and the adsorption of enzyme per unit volume [16]. Moreover, the non-covalent immobilization of NQ on graphite and MWCNTs matrix can be achieved by π – π interactions between the aromatic groups of quinones and MWCNTs/graphite surfaces, suppressing the NQ dissolution into liquid electrolyte and improving the electrode performance [17]. Regarding the cathode, PB/MWCNT hybrids were used as electrocatalysts because PB itself possesses a facile charge transfer [18]. The electrochemical characteristics of PB can be enhanced when it is combined with carbon-containing nanomaterials such as CNTs, graphene, and graphene oxide [19, 20]. Furthermore, the presence of MWCNTs in the ink can increase electron transfer between PB and the flexible electrode, thereby enhancing the electrochemical properties [21]. The π – π stacking can also be formed between the CNT sidewall and cyanide ligands of PB [22]. Since both carbon atoms in the sidewall of CNTs and the cyanide are conjugated, they could function as electron donor and acceptor, respectively. Therefore, high performances and stability of electrodes could be associated with the synergic effect between CNTs and PB [23].

A binder is essential to screen-printed ink's flexibility, adhesion and mechanical robustness. However, applying an excessive amount of the binder can compromise the electrode characteristics and result in a non-conductive network. In this study, the ink recipes were properly customized to maintain conductive property and mechanical strength. PU was chosen as the binder because of its elastomeric properties and ability to reinforce the conductive network after the electrode has been mechanically distorted [24]. The desirable property of PU is due to various functional groups (e.g., amino and carbonyl groups) on PU molecular chains; thus, it not only improves adhesion properties between ink formulation and substrate, but also allows MWCNTs to disperse evenly and form a three-dimensional (3D) conductive network in the inks [24]. Moreover, the type of solvent used in ink preparation also significantly affects the ink

homogeneity. In this work, THF was selected as a solvent, resulting in an optimal ink formulation with appropriate viscosity. This is because its dielectric constant is suitable to produce a colloidal-like ink, unlike other solvents (such as iso-propanol or ethylene glycol) which have a higher dielectric constant and produce a solvent-like ink [25].

It is necessary to agitate the agglomerates of solid materials during the dispersion of the ink components (containing solid contents and solvent) to enable the solid matter to be fully dispersed. In this work, the homogenizer probe was first used to disperse MWCNTs or PB/MWCNT nanocomposite in the solvent, then other contents were added and thoroughly mixed using a high-speed mixing machine. During the first step of dispersion, solid matter can be dispersed quickly by the homogenizer probe (less than 2 min). The use of a homogenizer probe to apply a mechanical shear force can breakdown the van de Waals potential energy between long nanotubes and can reduce the agglomerate diameter of solid contents resulting in more active sites. Reducing the agglomerate size can improve ink quality [26].

The ratio of ink components, which are conductive particles (MWCNTs and graphite), mediator (NQ), electrocatalyst (PB/MWCNT), polymer binder (PU), and solvent (THF), has been customized to realize good adhesion between ink formulations and substrates while maintaining high conductivity [27]. By squeezing the resulting ink through the opening areas of the stencil, electrode structures can be created on a wide range of surfaces and materials, including plastic, rubber, textile, and stretchable epidermal, as shown in Fig. 1c. Using a low curing temperature makes it possible to incorporate a variety of substrates without damaging them, making mass manufacturing of devices easier. Unlike other fabrication techniques, such as the light irradiation technique and electrostatic spray deposition, high temperatures may be required, rendering them incompatible with wearable substrates (such as textiles or soft thin films) because extreme conditions can damage the substrate surface [28].

Our BFC model utilizes the new ink formulations and bioelectrochemical reactions at the printed electrode surfaces to convert chemical energy into electrical energy, thereby generating current and power (Fig. 1d, top). This electrical energy from redox reactions is also proportional to fuel (glucose) concentration. Hence, the printed device can also act as a self-powered biosensor to determine the glucose concentration [4] (Fig. 1d, bottom).

3.2 Characterizations of the Anode

To investigate morphology of the screen-printed NQ/MWCNT-based electrode, scanning electron microscopy (SEM) was carried out. As shown in Fig. 2a, MWCNTs and graphite particles were dispersed uniformly in the anode. On the surface of the printed electrode, components were evenly spread without significant aggregates. The network formed between compositions, particularly MWCNTs, creates good electrical connections. Moreover, a structure with high porosity enhances electrochemical properties due to increased active sites and good electron transfer, and can accommodate biocatalytic components [29].

A cyclic voltammetry (CV) with a three-electrode system was used to evaluate the electrochemical performance of NQ/MWCNT-based electrode. The CV curve at a scan rate of 50 mV s^{-1} illustrated in Fig. 2b shows that NQ embedded in the printed matrix displays a quasi-reversible redox capability, with a formal potential ($E_{1/2}$) of -0.12 V in pH 7.0. This redox couple was assigned to the two electron/two proton redox conversion [30]. The obvious redox peak in this study agreed with a previous study of an enzymatic electrode using NQ as an electron mediator [31].

Figure 2c shows the CVs of a screen-printed NQ/MWCNT-based anode obtained in 0.1 M PBS, pH 7.0, with a varying scan rate from 10 to 200 mV s^{-1} . These plots




Fig. 2 Characterizations of the anode. **a** SEM images of a screen-printed NQ/MWCNT-based anode at (1) low and (2) high magnification. **b** CV obtained from a screen-printed NQ/MWCNT-based anode in 0.1 M PBS, pH 7.0 with a scan rate of 50 mV s^{-1} . **c** CVs obtained from a screen-printed NQ/MWCNT-based anode in 0.1 M PBS, pH 7.0 at different scan rates from 10 to 200 mV s^{-1} (scan rates (1–9): 10, 25, 50, 75, 100, 125, 150, 175 and 200 mV s^{-1}). **d** Plots of anodic peak current densities in function with square root of the scan rate obtained on a screen-printed NQ/MWCNT-based anode. **e** CVs obtained from a screen-printed GOx/NQ/MWCNT-based bioanode in (1–3) 0, 10, and 100 mM glucose in 0.1 M PBS, pH 7.0 with a scan rate of 5 mV s^{-1} . **f** Amperometric response of a screen-printed GOx/NQ/MWCNT-based bioanode with an applied potential of 0.3 V versus Ag/AgCl upon increasing the glucose concentrations ((1) 1.0 mM; (2) 1.5 mM; (3) 2.0 mM; (4) 5.0 mM; (5) 10 mM; (6) 20 mM; (7) 50 mM; (8) 100 mM; and (9) 150 mM). **g** The corresponding calibration plot of the current response of the GOx/NQ/MWCNT-based bioanode. **h** The double reciprocal plot of the calibration curve obtained from the GOx/NQ/MWCNT-based bioanode

indicate quasi-reversible NQ redox couples, and that the ratio of the anodic and cathodic peak currents (I_c/I_a ratio) is nearly one (ranging from 0.9 to 1.0). The CV shapes are well maintained, indicating that the NQ/MWCNT-based electrode has good rate performance. The resulting anodic and cathodic peak currents are proportional to the square root of the scan rate, as shown in Fig. 2d. This behavior follows the Randles–Sevcik equation [32] and indicates that the processes occurring on the NQ/MWCNT-based anode are diffusion-controlled, which agrees with a previous study of a NQ-modified electrode [33].

GOx was immobilized to the NQ/MWCNT-based surface, and CV technique was performed at a low scan rate (5 mV s^{-1}) to evaluate bioelectrocatalytic characteristics of the bioanode while minimizing the contribution of capacitive current caused by the large electroactive area of the ink's matrix. As can be seen from voltammograms given in Fig. 2e (dashed line), a reversible peak was observed at around -0.17 V in the absence of glucose. This redox behavior validates the immobilization of the enzyme and NQ on the surface of the bioanode. NQ could strongly functionalized in the inner matrix of the nanocomposite ink and some could be adsorbed at the surface, resulting in two overlapping reversible systems [34]. In the presence of glucose, the redox systems exhibit an increase in oxidation peak current at around 0 V while the reduction peak intensity decreases (Fig. 2e, solid line). This confirms that the electrochemical behavior of a screen-printed GOx/NQ/MWCNT-based bioanode upon adding glucose was due to an effective mediation by NQ and the enzyme immobilization incorporated in the conductive nano-matrix.

Furthermore, the electrocatalytic activity toward glucose oxidation on the GOx/NQ/MWCNT-based bioanode was investigated using an amperometric technique and increasing glucose concentrations (Fig. 2f). The result clearly shows that a rise in glucose concentration increases the anodic current. This is due to the effective contribution of the mediated glucose oxidation catalyzed by GOx. The current responses were observed over a wide range of $0\text{--}150 \text{ mM}$ glucose before reaching its limit. As shown in Fig. 2g, the calibration plot of a single bioanode as a mediated glucose biosensor shows a linearity in a range of $1.5\text{--}20 \text{ mM}$ glucose ($R^2 = 0.8988$). The linear range sensitivity was calculated to be $0.0073 \mu\text{A mM}^{-1}$. Additionally, a Michaelis–Menten dependence is apparent, which corresponds to enzymatic kinetics. As illustrated in Fig. 2h, the graph was

plotted in double reciprocal coordinates to transform the Michaelis–Menten equation (Eq. 1) algebraically into the Lineweaver–Burk equation (Eq. 2) [8]:

$$I = \frac{I_{\max}[C]}{K_m + [C]} \quad (1)$$

$$\frac{1}{I} = \frac{1}{I_{\max}} + \frac{K_m^{\text{app}}}{I_{\max}} \left(\frac{1}{C} \right) \quad (2)$$

where I is the steady-state current after the addition of glucose, $I_{\max}$ is the maximum current obtained from saturated glucose concentrations, C is the glucose concentration, and K_m^{app} is the apparent Michaelis–Menten constant (enzyme-substrate kinetic indicator). The K_m^{app} interpreted from the straight line of the double reciprocal plot (using the slope and y-intercept) was 2.47 mM . It has a lower value than glucose biosensors based on glucose oxidation previously reported [16, 35]. The small value confirmed high affinity of the GOx immobilized on the bioanode to glucose.

3.3 Characterizations of the Cathode

The morphology of a screen-printed PB/MWCNT-based cathode was characterized by SEM (Fig. 3a). The study reveals uniform PB nanoparticles with an average particle diameter of $\sim 250 \text{ nm}$ at the cathode surface. This structure results from the nucleation and growth of PB particles during PB synthesis [36]. The small rod of MWCNTs was dispersed uniformly between each PB nanoparticles attached to graphite surface, thus ensuring the good conductivity within the continuous conductive network [36].

Figure 3b shows EDX elemental analysis within PB/MWCNT-based cathode. It is clearly seen in the EDX mapping that iron (Fe) elements are present and uniformly distributed in the cathode ink compound (Fig. 3b2). The presence of Fe is also validated by the EDX spectrum (Fig. 3c); the Fe peaks observed in the cathode composite confirmed the successful synthesis of PB. Moreover, FTIR was further used to characterize PB/MWCNT composite. The functional groups present in the synthesized PB/MWCNT assigned to H–O–H bend of water, C $\equiv$ N stretch, O–H stretch of water, Fe–O bond and Fe $^{2+}$ –CN–Fe $^{3+}$ bend with the absorption peak at 3443 , 2084 , 1622 , 600 , and 502 cm^{-1} , respectively (Fig. 3d) [37, 38]. Note that the stretching vibration of C $\equiv$ N and Fe $^{2+}$ –CN–Fe $^{3+}$ bend are the typical signals of PB. –OH groups specifically at 3443 cm^{-1} are also found in MWCNTs;






Fig. 3 Characterizations of the cathode. **a** SEM images of a screen-printed PB/MWCNT-based cathode at (1) low magnification and (2) high magnification. **b** SEM image (1) with EDX mapping for (2) Fe elements in PB/MWCNT-based cathode. **c** EDX spectra of PB/MWCNT-based cathode. **d** FT-IR spectra of (1) MWCNT and (2) synthesized PB/MWCNT. **e** CVs obtained from (black line) the glassy carbon (GC) electrode and (red line) the PB/MWCNT-coated GC electrode in 0.1 M PBS, pH 7.0 with a scan rate of 50 mV s⁻¹. **f** CVs obtained from a screen-printed PB/MWCNT-based cathode in 0.1 M PBS, pH 7.0 at different scan rates from 10 to 200 mV s⁻¹ (scan rates (1–9): 10, 25, 50, 75, 100, 125, 150, 175 and 200 mV s⁻¹). **g** Plots of cathodic peak current densities in function with square root of the scan rate obtained on a screen-printed PB/MWCNT-based cathode. **h** LSVs obtained from a screen-printed PB/MWCNT-based cathode in the presence of H₂O₂ ((1) blank; (2) 0.5 mM; (3) 2 mM; and (4) 5 mM) in 0.1 M PBS, pH 7.0 with a scan rate of 5 mV s⁻¹. **i** Amperometric response of a screen-printed GOx/PB/MWCNT-based biocathode with an applied potential of 0 V versus Ag/AgCl upon increasing the glucose concentrations ((1) 0.1 mM; (2) 0.2 mM; (3) 0.5 mM; (4) 1 mM; (5) 1.5 mM; (6) 2 mM; (7) 5 mM; (8) 10 mM; (9) 20 mM; and (10) 50 mM). **j** The corresponding calibration plot of the current response of the GOx/PB/MWCNT-based biocathode. **k** The double reciprocal plot of the calibration curve obtained from the GOx/PB/MWCNT-based biocathode. (Color figure online)

this may be introduced during the manufacturing process from raw materials [39]. The hydroxyl bending band specifically

at 1622 cm⁻¹ can be caused by MWCNT surface as well as an internal moisture left over from the PB synthesis process.

We also characterized the electrochemical behavior of the synthesized PB/MWCNT (Fig. 3e). Two redox pairs, clearly observed in the CV, were related to two reversible redox reactions: Prussian white (PW) $\rightleftharpoons$ Prussian blue (PB) (redox reaction of $\text{Fe}^{3+/2+}$) and Prussian blue (PB) $\rightleftharpoons$ Berlin green (BG) (redox reaction of $\text{Fe}(\text{CN})_6^{3-/4-}$) [40, 41]. Regarding the mechanism of H_2O_2 reduction on a PB-containing biocathode, PB can be electrochemically reduced to generate Prussian white (PW), which can catalyze the reduction of H_2O_2 at a low potential [42]. PW is then oxidized back to PB. This reversible electrochemical redox property of PB allows it to act as an efficient catalyst throughout the entire electrochemical reactions on the printed cathode.

Figure 3f shows the CVs of a screen-printed PB/MWCNT-based cathode obtained in 0.1 M PBS, pH 7.0, with varying scan rates from 10 to 200 mV s^{-1} . These plots indicate quasi-reversible redox reaction of $\text{Fe}^{3+/2+}$ in PB, and that the ratio of the anodic and cathodic peak currents (I_c/I_a ratio) is nearly one (ranging from 0.9 to 1.1). The well-preserved CV shapes can be observed, and the values of E_{pa} and E_{pc} shift slightly to the positive and negative directions, respectively. The resulting anodic and cathodic peak currents are proportional to the square root of the scan rate, as shown in Fig. 3g. This behavior indicates that the processes occurring on the PB/MWCNT-based electrode are diffusion-controlled, which agrees with a previous study of a PB-modified electrode [42].

The electrochemical detection of H_2O_2 on a screen-printed PB/MWCNT-based cathode was investigated by a linear sweep voltammetry technique (LSV). Figure 3h shows that the presence of H_2O_2 results in a significant increase in cathodic current, which corresponds to H_2O_2 reduction at ~ 80 mV versus Ag/AgCl. In addition, an amperometric technique was performed to investigate the electrocatalytic reduction of H_2O_2 on the cathode. Figure S1 depicts the cathodic response with successive addition of H_2O_2 . The corresponding calibration plot shows a good linearity in the range of 0.25–10 mM with the sensitivity of $9.76 \mu\text{A mM}^{-1}$. The results clearly demonstrate that the PB/MWCNT-based electrode can be efficient in reducing H_2O_2 in a BFC cathode or a conventional peroxide-based biosensor.

Furthermore, an amperometric technique was used to evaluate the catalytic current of the biocathode which was immobilized with GOx. Figure 3i shows that the reduction current increased upon the increase of glucose concentrations from 0.1 to 50 mM. The increase in cathodic current

corresponds to the generated H_2O_2 (i.e., a by-product of glucose oxidation), reduced by the PB electrocatalyst in the biocathode ink's nanocomposite. The calibration plot of a single biocathode shows a good linearity in a range of 1.5–20 mM glucose ($R^2 = 0.9645$), as shown in Fig. 3j. The sensitivity of analysis assessed from the linear range was $0.4738 \mu\text{A mM}^{-1}$. The K_m^{app} value on the biocathode was 2.99 mM (interpreted from the double reciprocal plot (Fig. 3k)). This was comparable with the report of a PB/MWCNT-modified electrode for glucose detection [43]. The K_m^{app} value of the biocathode was not significantly different from that of the bioanode; consequently, the proposed enzymatic BFCs could provide a high GOx affinity toward glucose.

3.4 Electrochemical Reaction Kinetics of the Flexible and Printed Electrodes

To understand the additional charge-storage behavior and electrochemical reaction kinetics of the anode and the cathode, we further analyzed the CVs curves from Figs. 2c and 3f. It is obvious from the CVs that both the NQ/MWCNT-based anode and the PB/MWCNT-based cathode showed a definite redox peak, showing that redox plays a major role in capacitance. As current varies depending on different scan rates, the charge stored by the Faradaic diffusion-controlled or capacitive contributions can be determined by a b -value [44], which can be derived from the power law equation, see the Supporting Information Note 1. The b -values of the anode are 0.58 for anodic and cathodic currents, indicating the operating mechanism is dominated by a semi-infinite diffusion process (Fig. S2a), see the Supporting Information Note 1 for b -values derivation. This corresponds to the earlier discussion in Fig. 2d which displays that the current risen proportionately with $v^{1/2}$ due to a diffusion-controlled process at the inner nano-structured surface. The b -values of the cathode are 0.75 and 0.68 for anodic and cathodic current, respectively, indicating the operating mechanism is mainly dominated by diffusion (Fig. S3a).

Furthermore, the CVs curve from Figs. 2c and 3f was analyzed to find the capacitive contribution. The areal capacitance (C_{areal}) of NQ/MWCNT-based anode and PB/MWCNT-based cathode from CVs can be estimated, see the Supporting Information Note 2. Figures S2b and S3b



shows the areal capacitance of NQ/MWCNT-based anode and PB/MWCNT-based cathode as a function of the scan rate. Both electrodes had the highest areal capacitance at the low scan rate (10 mV s^{-1}) and the lowest areal capacitance at the high scan rate (200 mV s^{-1}). This is because low scan rates allow the electrolyte ions to diffuse into internal microscopic pores of the printed electrode, which leads to high capacitance at the electrolyte-nanocomposite interface. Capacitance decreases at high scan rates due to slower charge/discharge characteristics. However, the areal capacitance of the anode was higher than the cathode and seemed to be stable after scan rate of 100 mV s^{-1} . The capacitance retention rates were 21.8% and 63.4% at scan rate of 200 mV s^{-1} for anode and cathode, respectively. The higher areal capacitance of the anode suggested that nanostructure of its ink's components (MWCNTs network linked within graphite sheets, as shown in Fig. 2a) served as a highly conductive matrix for fast electron transport, while the lower areal capacitance of the cathode might probably be due to bigger size of PB nanoparticles on graphite sheets as shown in Fig. 3a.

To distinguish the faradaic and capacitive charge-storage contributions on each electrode, the CVs curves from Figs. 2c and 3f was analyzed followed the relation that overall current can be expressed as sum of capacitive current and faradaic current, see the Supporting Information Note 3 for details. The current response of a CV can be partitioned into faradaic and capacitive charge storage, as can be seen in Figs. S2c and S3c for the NQ/MWCNT-based anode and the PB/MWCNT-based cathode, respectively, at the scan rate of 10 mV s^{-1} . In the pink region, the contribution of faradaic current is assessed, while capacitive current is estimated in the green region. At the low scan rate (10 mV s^{-1}), it is evident that the faradaic charge-storage mechanism (diffusion-limited process) predominates over the capacitive charge-storage mechanism. We investigated further to a fast scan rate of 200 mV s^{-1} and discovered that the capacitive current was more dominant at a higher scan rate because diffusion limitation hinders the ability for electrolyte ions to diffuse into electrode inner layer (Figs. S2d and S3d). This clearly aligns with the areal capacitance trend observed in Figs. S2b and S3b. The presence of PB/MWCNT hybrid has a relatively important contribution to capacitive charge-storage characteristics.

3.5 Studies of the BFC and the Self-powered Glucose Biosensor

Glucose was selected as a biofuel model in our BFC development because it is one of the primary constituents in human biofluids, including sweat, and glucose is specifically oxidized using commercially available glucose oxidase (GOx) in catalytic electrochemical reactions, converting chemical energy to electrical energy [4, 45]. In general, the level of glucose in blood can indicate diabetes, a chronic condition caused by an insulin insufficiency [46]. However, traditional sensors for glucose detection rely on invasive blood sample methods which are painful and inconvenient. Interestingly, glucose monitoring reveals a link between glucose levels in diabetic patients' blood and sweat [47, 48]. Therefore, researchers are exploring noninvasive sensors as glucose monitoring diagnostic tools [49]. We also aim to apply this glucose BFC-based device serving as an energy harvester to display self-powered glucose biosensing signal by investigating the relationship between glucose concentration and electrical outputs.

The performance of a screen-printed glucose BFC was evaluated by using the GOx/NQ/MWCNT-based bioanode coupled with the GOx/PB/MWCNT-based biocathode in different glucose concentrations. Figure 4a and b shows that glucose concentration affects both current density and power output. The maximum current density and power output obtained reached around 1.3 mA cm^{-2} and $266 \text{ } \mu\text{W cm}^{-2}$, respectively, at a voltage of 0.20 V. An open circuit voltage of 0.45 V was obtained in the presence of 20 mM glucose. This power output was reasonable for future applications of a DC-DC converter or low-power consumption electronics that could communicate wirelessly through radio frequency (RF) circuits [50]. The high current density and high-power density were obtained because of the customized nanocomposite inks in both anode and cathode, which have desirable electrical conductivity and electrocatalytic properties. MWCNTs and PB/MWCNT hybrid make it easier for electrons to pass from the anode to the cathode, leading to the high power output [21, 51]. Figure 4c shows a good relationship between the increasing concentrations of glucose and power density in a range of 0–20 mM glucose, with a good sensitivity ($2.1 \pm 0.1 \text{ } \mu\text{W cm}^{-2} \text{ mM}^{-1}$) and a correlation coefficient of 0.9812.

The screen-printed glucose BFC was investigated as a self-powered glucose biosensor. An external load was




Fig. 4 A BFC and a self-powered glucose biosensor. **a** Polarization curves of a screen-printed glucose BFC at different glucose concentrations ((1) blank; (2) 1 mM; (3) 2 mM; (4) 5 mM; (5) 10 mM; and (6) 20 mM) in 0.1 M PBS, pH 7.0. **b** Power density versus potential plots of a screen-printed glucose BFC at different glucose concentrations (1) blank; (2) 1 mM; (3) 2 mM; (4) 5 mM; (5) 10 mM; and (6) 20 mM) in 0.1 M PBS, pH 7.0. **c** The corresponding calibration plot of power and glucose concentrations. **d** Schematic illustration of the self-powered biosensing electronic system. **e** The self-generated current response obtained from a screen-printed glucose BFC, with no applied potential upon increasing the glucose concentrations (0, 0.05, 0.1, 0.5, 1, 1.5, 2, 5 and 10 mM) in 0.1 M PBS, pH 7.0. The current was observed at a constant load between electrodes of 99.7 kΩ. **f** The corresponding calibration plot of the current response and glucose concentrations of a screen-printed glucose BFC

connected to BFC without the requirement of any external applied voltage, as illustrated in Fig. 4d. The current response generated by the BFC itself with successive additions of glucose in a range of 0–10 mM was observed (Fig. 4e, f). The calibration plot of the self-generated current signal showed a linearity up to 1.5 mM glucose ($R^2 = 0.8703$), with a sensitivity of $0.026 \pm 0.004 \mu\text{A cm}^{-2} \text{ mM}^{-1}$. The good sensitivity in one flexible and simplified cell enables the BFC to function in a self-powered mode and be used to measure glucose concentration. The comparison between our screen-printed glucose BFC and other glucose BFC is also demonstrated in Table S2. Moreover, taking other BFCs into consideration, when BFCs are integrated with the use of other costly enzymes such as laccase [52] and bilirubin oxidase [53], it is clear that the cost of BFC fabrication appears to be higher. In addition, several of them have not been evaluated in sweat or biofluid models [7]. Additionally, the electrochemical measurements of previous published studies were tested only using a rigid electrode [10]; the ability to integrate flexible materials was not much studied.

3.6 Selectivity Study of the Self-powered Biosensor

The selectivity of a screen-printed glucose BFC was investigated by measuring the self-generated current output in the presence of the normal level of common constituents available in human sweat that might be anticipated to interfere to the determination of glucose [54]. As shown in Fig. 5a, a screen-printed glucose BFC provided high selectivity in the presence of lactate, uric acid, ascorbic acid, and creatinine. The self-generated current output shows only a slight change when interferences were added compared to the addition of the glucose target to the wearable system because of the specificity of GOx-based BFC to glucose and no extra application of any overvoltage.

Wireless technology is important for the communication between sensor units and users since it allows to access real-time digital information. Using a wireless voltmeter, the voltage output of BFCs can be transformed into an analytical signal that can be transmitted wirelessly to portable devices such as a smartphone, thereby meeting the practical requirements of their real-life wearable operation. To demonstrate




Fig. 5 Applications of a flexible single-enzyme-based energy-harvesting device and self-powered biosensors. **a** The self-generated current response obtained from a screen-printed glucose BFC, with no applied potential upon interferences adding (14 mM lactate, 59 μ M uric acid, 10 μ M ascorbic acid, and 84 μ M creatinine). The current was observed at a constant load between electrodes of 99.7 k Ω . **b** Schematic illustration of a screen-printed glucose BFC on a stretchable textile of the arm sleeve together with a circuit of the system. **c** The self-generated voltage output obtained from a screen-printed glucose BFC and a wireless voltmeter, with no applied potential upon increasing the glucose concentrations (0, 0.2, 0.5, 1, 5 and 10 mM) in artificial sweat. The voltage was observed at a constant load between electrodes of 99.7 k Ω . **d** The corresponding calibration plot of self-generated voltage output and glucose concentrations. **e** The double reciprocal plot of the calibration curve (background subtraction). **f** The operational stability of a screen-printed glucose BFC in the presence of 5 mM glucose in artificial sweat over 15 h with a schematic illustration of the testing cell and a circuitry system

this concept of a wearable and flexible biosensor, the BFC was printed on an arm sleeve and designed to measure sweat on-body, obtaining real-time data via a wireless device. The system includes a screen-printed BFC, a resistor as a load, and the compact wireless device for voltage output measuring (Fig. 5b). The voltage response obtained from a portable wireless system generated by the BFC itself with successive additions of glucose in a range of 0–10 mM in artificial sweat is illustrated in Fig. 5c. Nonlinear regression algorithms have been used to generate the calibration plot of the self-generated voltage output by using the modified Michaelis–Menten equation (Supporting Information

Note 4). The calibration plot of the self-generated voltage output showed a good relationship with the increasing glucose concentration over a range of 0–10 mM glucose, with $R^2 = 0.9737$ (Fig. 5d). This curve shows that self-generated voltage increases rapidly during the initial phase of glucose (fuel) addition, then slowly before reaching their limit. The maximum potential was attained at high glucose (substrate) concentrations due to enzyme saturation, which means that it is entirely in enzyme–substrate complex form and that adding glucose has no effect on the voltage generation. The maximum voltage obtained from the nonlinear calibration plot was comparable to the value obtained from the double

reciprocal plot's regression, which gives a good linear relationship result (Fig. 5e).

In wearable applications, the long-term and operational stabilities are of particular concern. Continuous operational stability was investigated in a batch system containing glucose in artificial sweat. The BFC showed an increase of self-generated voltage in the very first hours followed by a slow decrease after 10th hour (Fig. 5f). The enhanced voltage output observed during the initial period may reflect the H_2O_2 accumulation in the testing cell. These voltage outputs suggest that the BFC was still functional after long-term operation.

3.7 Mechanical Resiliency

It is important for printed materials to be resilient to mechanical deformations to meet their applicability. Therefore, the effect of mechanical bending was investigated using the electrodes screen-printed on a PET material. Figure 6a shows the variation of resistance of a screen-printed anode and cathode after being bent repeatedly from 0° to 90° to 180° and back to their relaxation state at a rate of 8 s per bending cycle. When the electrode was bent from 0° to 90° , the resistance change (R/R_0) value increased slightly from the initial value, varying in a range of 0.9–1.1 for the anode and the cathode.

The resistance increased with the bending degree; R/R_0 ranging between 0.8 and 1.2 for the anode the cathode at 180° . However, this occurred only during bending; after relaxing to 0° , the resistance returned to its initial value. To further confirm the ability of the BFC in practice use scenario, it was repeatedly carried out electrochemical endurance evaluation under multiple bending at 180° for 150 times in the presence of glucose in artificial sweat (Fig. 6b). Potential and current response generated by the BFC itself remained constant up to 90 times of bending, followed by maintaining over 83% performance after 100 bending cycles. After repetitive mechanical deformations, no substantial fatigue failure was observed for electrical and electrochemical aspects. This could be because when the electrode is bent, the distance between the conductive particles (MWNCTs and graphite) changes on a microscopic scale and the distance between the conductive particles increases (a larger gap between the conductive materials), thereby increasing the resistance of the electrode. However, after relaxing, elastomer polymer (i.e., PU) can assist in reestablishing the percolation network of conductive particles, facilitating the electrical current to move through the electrode. This indicates that our screen-printable inks have highly stable performances and mechanical resilience, suitable for wearable and various applications.




Fig. 6 Electrical and electrochemical endurance of the printed device under multiple deformations. **a** The repetitive mechanical deformations of a screen-printed anode and cathode on PET material at 0° , 90° , 180° , and 0° bending. **b** The voltage output and current obtained from a screen-printed glucose BFC with no applied potential in the presence of 5 mM glucose in artificial sweat after a series of deformation at 180° bending. The voltage was observed at a constant load between electrodes of 99.7 k Ω



4 Conclusion

This work demonstrated an example of screen-printable functional inks developed for a membraneless single-enzyme-based energy-harvesting device and a self-powered biosensor, powered by the same substrate (glucose) for both electrodes. The bioanode reaction relied on glucose oxidation, whereas the biocathode relied on the reduction of H_2O_2 . The single-enzyme BFC exhibited an OCV of 0.45 V with a maximum power density of $266 \mu\text{W cm}^{-2}$ and current density of $\sim 1.3 \text{ mA cm}^{-2}$ at 20 mM glucose. The BFC was successfully used to harvest energy from artificial sweat as a representative of epidermal energy-harvesting and a self-powered glucose biosensor in real-life situations. In addition, the system had good operational stability for many hours. By creating novel screen-printable inks, the sensor enables the incorporation of a wide variety of substrates, including rubber, plastic, epidermal tattoo, and stretchable textile and the mechanical resiliency was good for electrodes printed on PET (as a representative flexible substrate). These characteristics hold great promise for on-body, noninvasive, self-powered biosensing, and energy-harvesting applications. Further study could focus on the functionality and endurance of inks screen-printed on other different substrates. Scaling up the ink preparation process for industrialization is also important to make this idea realistic for the next generation of flexible bioelectronics. It is possible to leverage this device by integrating with other on-body or wireless bioelectronics to track motion and monitor others biochemicals. Moreover, it is possible to leverage the design of energy-efficient microsystems by focusing on the design of RF circuits, power converters, and sensor interfaces for miniaturized systems and biomedical applications.

Acknowledgements This research was supported by National Research Council of Thailand (NRCT (grant number: N41A640129), Prince of Songkla University, Hat Yai, Thailand. We would like to thank the Talent Management Project of Prince of Songkla University. We also gratefully acknowledge the Center of Excellence for Innovation in Chemistry (PERCH-CIC), Ministry of Higher Education, Science, Research, and Innovation (MHESI).

Funding Open access funding provided by Shanghai Jiao Tong University.

Open Access This article is licensed under a Creative Commons Attribution 4.0 International License, which permits use, sharing,

adaptation, distribution and reproduction in any medium or format, as long as you give appropriate credit to the original author(s) and the source, provide a link to the Creative Commons licence, and indicate if changes were made. The images or other third party material in this article are included in the article's Creative Commons licence, unless indicated otherwise in a credit line to the material. If material is not included in the article's Creative Commons licence and your intended use is not permitted by statutory regulation or exceeds the permitted use, you will need to obtain permission directly from the copyright holder. To view a copy of this licence, visit <http://creativecommons.org/licenses/by/4.0/>.

Supplementary Information The online version contains supplementary material available at <https://doi.org/10.1007/s40820-023-01045-1>.

References

1. H. Wu, Y. Zhang, A.L. Kjøniksen, X. Zhou, X. Zhou, Wearable biofuel cells: advances from fabrication to application. *Adv. Funct. Mater.* **31**, 2103976 (2021). <https://doi.org/10.1002/adfm.202103976>
2. R. Liu, Z.L. Wang, K. Fukuda, T. Someya, Flexible self-charging power sources. *Nat. Rev. Mater.* **7**, 870–886 (2022). <https://doi.org/10.1038/s41578-022-00441-0>
3. J. Janek, W.G. Zeier, A solid future for battery development. *Nat. Energy* **1**, 16141 (2016). <https://doi.org/10.1038/nenergy.2016.141>
4. I. Jeerapan, J.R. Sempionatto, J. Wang, On-body bioelectronics: wearable biofuel cells for bioenergy harvesting and self-powered biosensing. *Adv. Funct. Mater.* **30**, 1906243 (2020). <https://doi.org/10.1002/adfm.201906243>
5. A. Zebda, J.P. Alcaraz, P. Vadgama, S. Shleev, S.D. Minteer, F. Boucher et al., Challenges for successful implantation of biofuel cells. *Bioelectrochemistry* **124**, 57–72 (2018). <https://doi.org/10.1016/j.bioelechem.2018.05.011>
6. E. Paz, N.H. Maganti, A. Trifonov, I. Jeerapan, K. Mahato et al., A self-powered ingestible wireless biosensing system for real-time in situ monitoring of gastrointestinal tract metabolites. *Nat. Commun.* **13**, 7405 (2022). <https://doi.org/10.1038/s41467-022-35074-y>
7. A. Kausaite-Minkstiniene, A. Kaminskas, A. Ramana-viciene, Development of a membraneless single-enzyme biofuel cell powered by glucose. *Biosens. Bioelectr.* **216**, 114657 (2022). <https://doi.org/10.1016/j.bios.2022.114657>
8. A.N. Sekretaryova, V. Beni, M. Eriksson, A.A. Karyakin, A.P.F. Turner et al., Cholesterol self-powered biosensor. *Anal. Chem.* **86**, 9540–9547 (2014). <https://doi.org/10.1021/ac501699p>
9. W. Zhang, H. Guan, T. Zhong, T. Zhao, L. Xing et al., Wearable battery-free perspiration analyzing sites based on sweat flowing on ZnO nanoarrays. *Nano-Micro Lett.* **12**, 105 (2020). <https://doi.org/10.1007/s40820-020-00441-1>

10. V. Krikstolaityte, Y. Oztekin, J. Kuliesius, A. Ramanašienė, Z. Yazıcıgil et al., Biofuel cell based on anode and cathode modified by glucose oxidase. *Electroanalysis* **25**, 2677–2683 (2013). <https://doi.org/10.1002/elan.201300482>
11. H. Lee, Y.J. Hong, S. Baik, T. Hyeon, D.H. Kim, Enzyme-based glucose sensor: from invasive to wearable device. *Adv. Healthc. Mater.* **7**, e1701150 (2018). <https://doi.org/10.1002/adhm.201701150>
12. W. Chen, S. Cai, Q.Q. Ren, W. Wen, Y.D. Zhao, Recent advances in electrochemical sensing for hydrogen peroxide: a review. *Analyst* **137**, 49–58 (2012). <https://doi.org/10.1039/C1AN15738H>
13. J. Kim, R. Kumar, A.J. Bandodkar, J. Wang, Advanced materials for printed wearable electrochemical devices: a review. *Adv. Electron. Mater.* **3**, 1600260 (2017). <https://doi.org/10.1002/aelm.201600260>
14. D.D.L. Chung, Review graphite. *J. Mater. Sci.* **37**, 1475–1489 (2002). <https://doi.org/10.1023/A:1014915307738>
15. J. Wang, Carbon-nanotube based electrochemical biosensors: a review. *Electroanalysis* **17**, 7–14 (2005). <https://doi.org/10.1002/elan.200403113>
16. B. Reuillard, A. Le Goff, C. Agnès, M. Holzinger, A. Zebda et al., High power enzymatic biofuel cell based on naphthoquinone-mediated oxidation of glucose by glucose oxidase in a carbon nanotube 3d matrix. *Phys. Chem. Chem. Phys.* **15**, 4892–4896 (2013). <https://doi.org/10.1039/C3CP50767J>
17. C. Han, H. Li, R. Shi, T. Zhang, J. Tong et al., Organic quinones towards advanced electrochemical energy storage: recent advances and challenges. *J. Mater. Chem. A* **7**, 23378–23415 (2019). <https://doi.org/10.1039/C9TA05252F>
18. K. Itaya, T. Ataka, S. Toshima, Spectroelectrochemistry and electrochemical preparation method of prussian blue modified electrodes. *J. Am. Chem. Soc.* **104**, 4767–4772 (1982). <https://doi.org/10.1021/ja00382a006>
19. S. Husmann, E. Nossol, A.J.G. Zarbin, Carbon nanotube/prussian blue paste electrodes: characterization and study of key parameters for application as sensors for determination of low concentration of hydrogen peroxide. *Sens. Actuat. B Chem.* **192**, 782–790 (2014). <https://doi.org/10.1016/j.snb.2013.10.074>
20. T.A. Vieira, J.R. Souza, D.T. Gimenes, R.A.A. Munoz, E. Nossol, Tuning electrochemical and morphological properties of prussian blue/carbon nanotubes films through scan rate in cyclic voltammetry. *Solid State Ion.* **338**, 5–11 (2019). <https://doi.org/10.1016/j.ssi.2019.04.026>
21. J. Zhai, Y. Zhai, D. Wen, S. Dong, Prussian blue/multiwalled carbon nanotube hybrids: synthesis, assembly and electrochemical behavior. *Electroanalysis* **21**, 2207–2212 (2009). <https://doi.org/10.1002/elan.200904680>
22. Y. Zhang, Y. Wen, Y. Liu, D. Li, J. Li, Functionalization of single-walled carbon nanotubes with prussian blue. *Electrochem. Commun.* **6**, 1180–1184 (2004). <https://doi.org/10.1016/j.elecom.2004.09.016>
23. D.T. Gimenes, E. Nossol, Effect of light source and applied potential in the electrochemical synthesis of prussian blue on carbon nanotubes. *Electrochim. Acta* **251**, 513–521 (2017). <https://doi.org/10.1016/j.electacta.2017.08.142>
24. L. Jiang, H. Hong, J. Hu, Facile thermoplastic polyurethane-based multi-walled carbon nanotube ink for fabrication of screen-printed fabric electrodes of wearable e-textiles with high adhesion and resistance stability under large deformation. *Text. Res. J.* **91**, 2487–2499 (2021). <https://doi.org/10.1177/00405175211008613>
25. B. Millington, S. Du, B.G. Pollet, The effect of materials on proton exchange membrane fuel cell electrode performance. *J. Power Sour.* **196**, 9013–9017 (2011). <https://doi.org/10.1016/j.jpowsour.2010.12.043>
26. B. Li, Y. Liu, Y. Guo, D. Yang, D. Yang et al., Controlling the microscopic morphology and permeability of catalyst layers in proton exchange membrane fuel cells by adjusting catalyst ink agglomerates. *Int. J. Hydrog. Energy* **46**, 32215–32225 (2021). <https://doi.org/10.1016/j.ijhydene.2021.06.216>
27. I. Jeerapan, J.R. Sempionatto, A. Pavinatto, J.M. You, J. Wang, Stretchable biofuel cells as wearable textile-based self-powered sensors. *J. Mater. Chem. A* **4**, 18342–18353 (2016). <https://doi.org/10.1039/C6TA08358G>
28. W. Lai, Y. Wang, X. Wang, A. Nairan, C. Yang, Fabrication and engineering of nanostructured supercapacitor electrodes using electromagnetic field-based techniques. *Adv. Mater. Technol.* **3**, 1700168 (2018). <https://doi.org/10.1002/admt.201700168>
29. P. Pinyou, V. Blay, L.M. Muresan, T. Noguer, Enzyme-modified electrodes for biosensors and biofuel cells. *Mater. Horiz.* **6**, 1336–1358 (2019). <https://doi.org/10.1039/C9MH00013E>
30. K. Oka, S. Murao, K. Kobayashi, H. Nishide, K. Oyaizu, Charge- and proton-storage capability of naphthoquinone-substituted poly(allylamine) as electrode-active material for polymer–air secondary batteries. *ACS Appl. Energy Mater.* **3**, 12019–12024 (2020). <https://doi.org/10.1021/acsaem.0c02178>
31. Y. Yang, Y. Su, X. Zhu, D. Ye, R. Chen et al., Flexible enzymatic biofuel cell based on 1, 4-naphthoquinone/mwcnt-modified bio-anode and polyvinyl alcohol hydrogel electrolyte. *Biosens. Bioelectron.* **198**, 113833 (2022). <https://doi.org/10.1016/j.bios.2021.113833>
32. N. Elgrishi, K.J. Rountree, B.D. McCarthy, E.S. Rountree, T.T. Eisenhart et al., A practical beginner's guide to cyclic voltammetry. *J. Chem. Educ.* **95**, 197–206 (2018). <https://doi.org/10.1021/acs.jchemed.7b00361>
33. S.M. Golabi, J.B. Raoof, Catalysis of dioxygen reduction to hydrogen peroxide at the surface of carbon paste electrodes modified by 1,4-naphthoquinone and some of its derivatives. *J. Electroanal. Chem.* **416**, 75–82 (1996). [https://doi.org/10.1016/S0022-0728\(96\)04728-6](https://doi.org/10.1016/S0022-0728(96)04728-6)
34. A.X. Oliveira, S.M. Silva, F.R.F. Leite, L.T. Kubota, F.S. Damos et al., Highly sensitive and selective basal plane pyrolytic graphite electrode modified with 1,4-naphthoquinone/mwcnt for simultaneous determination of dopamine, ascorbate and urate. *Electroanalysis* **25**, 723–731 (2013). <https://doi.org/10.1002/elan.201200515>
35. J. Zang, C.M. Li, X. Cui, J. Wang, X. Sun et al., Tailoring zinc oxide nanowires for high performance amperometric glucose



- sensor. *Electroanalysis* **19**, 1008–1014 (2007). <https://doi.org/10.1002/elan.200603808>
36. Y. You, H.R. Yao, S. Xin, Y.X. Yin, T.T. Zuo et al., Subzero-temperature cathode for a sodium-ion battery. *Adv. Mater.* **28**, 7243–7248 (2016). <https://doi.org/10.1002/adma.201600846>
 37. P.J. Kulesza, M.A. Malik, A. Denca, J. Strojek, In situ ft-ir/atr spectroelectrochemistry of prussian blue in the solid state. *Anal. Chem.* **68**, 2442–2446 (1996). <https://doi.org/10.1021/ac950380k>
 38. L. Chang, S. Chang, W. Chen, W. Han, Z. Li et al., Facile one-pot synthesis of magnetic prussian blue core/shell nanoparticles for radioactive cesium removal. *RSC Adv.* **6**, 96223–96228 (2016). <https://doi.org/10.1039/C6RA17525B>
 39. F. Avilés, J.V. Cauich-Rodríguez, L. Moo-Tah, A. May-Pat, R. Vargas-Coronado, Evaluation of mild acid oxidation treatments for mwcnt functionalization. *Carbon* **47**, 2970–2975 (2009). <https://doi.org/10.1016/j.carbon.2009.06.044>
 40. A.A. Karyakin, Prussian blue and its analogues: electrochemistry and analytical applications. *Electroanalysis* **13**, 813–819 (2001). [https://doi.org/10.1002/1521-4109\(200106\)13:10%3c813::AID-ELAN813%3e3.0.CO;2-Z](https://doi.org/10.1002/1521-4109(200106)13:10%3c813::AID-ELAN813%3e3.0.CO;2-Z)
 41. B. Kong, C. Selomulya, G. Zheng, D. Zhao, New faces of porous prussian blue: interfacial assembly of integrated hetero-structures for sensing applications. *Chem. Soc. Rev.* **44**, 7997–8018 (2015). <https://doi.org/10.1039/C5CS00397K>
 42. S. Cinti, F. Arduini, D. Moscone, G. Palleschi, A.J. Killard, Development of a hydrogen peroxide sensor based on screen-printed electrodes modified with inkjet-printed prussian blue nanoparticles. *Sensors (Basel)* **14**, 14222–14234 (2014). <https://doi.org/10.3390/s140814222>
 43. X. Che, R. Yuan, Y. Chai, J. Li, Z. Song et al., A glucose biosensor based on chitosan–prussian blue–multiwall carbon nanotubes–hollow ptco nanochains formed by one-step electrodeposition. *Colloids Surf. B* **84**, 454–461 (2011). <https://doi.org/10.1016/j.colsurfb.2011.01.041>
 44. Z. Tian, X. Tong, G. Sheng, Y. Shao, L. Yu et al., Printable magnesium ion quasi-solid-state asymmetric supercapacitors for flexible solar-charging integrated units. *Nat. Commun.* **10**, 4913 (2019). <https://doi.org/10.1038/s41467-019-12900-4>
 45. N. Mano, Engineering glucose oxidase for bioelectrochemical applications. *Bioelectrochemistry* **128**, 218–240 (2019). <https://doi.org/10.1016/j.bioelechem.2019.04.015>
 46. J. Wang, Electrochemical glucose biosensors. *Chem. Rev.* **108**, 814–825 (2008). <https://doi.org/10.1021/cr068123a>
 47. J. Moyer, D. Wilson, I. Finkelshtein, B. Wong, R. Potts, Correlation between sweat glucose and blood glucose in subjects with diabetes. *Diabetes Technol. Ther.* **14**, 398–402 (2012). <https://doi.org/10.1089/dia.2011.0262>
 48. A.J. Bandodkar, P. Gutruf, J. Choi, K. Lee, Y. Sekine et al., Battery-free, skin-interfaced microfluidic/electronic systems for simultaneous electrochemical, colorimetric, and volumetric analysis of sweat. *Sci. Adv.* **5**, eaav3294 (2019). <https://doi.org/10.1126/sciadv.aav3294>
 49. A.J. Bandodkar, W. Jia, C. Yardımcı, X. Wang, J. Ramirez et al., Tattoo-based noninvasive glucose monitoring: a proof-of-concept study. *Anal. Chem.* **87**, 394–398 (2015). <https://doi.org/10.1021/ac504300n>
 50. A.F. Yeknami, X. Wang, I. Jeerapan, S. Imani, A. Nikoofard et al., A 0.3–v cmos biofuel-cell-powered wireless glucose/lactate biosensing system. *JSSC* **53**, 3126–3139 (2018). <https://doi.org/10.1109/JSSC.2018.2869569>
 51. E.S. Goda, S. Lee, M. Sohail, K.R. Yoon, Prussian blue and its analogues as advanced supercapacitor electrodes. *J. Energy Chem.* **50**, 206–229 (2020). <https://doi.org/10.1016/j.jechem.2020.03.031>
 52. X. Li, D. Li, Y. Zhang, P. Lv, Q. Feng et al., Encapsulation of enzyme by metal-organic framework for single-enzymatic biofuel cell-based self-powered biosensor. *Nano Energy* **68**, 104308 (2020). <https://doi.org/10.1016/j.nanoen.2019.104308>
 53. P. Pinyou, F. Conzuelo, K. Sliozberg, J. Vivekananthan, A. Contin et al., Coupling of an enzymatic biofuel cell to an electrochemical cell for self-powered glucose sensing with optical readout. *Bioelectrochemistry* **106**, 22–27 (2015). <https://doi.org/10.1016/j.bioelechem.2015.04.003>
 54. C.J. Harvey, R.F. LeBouf, A.B. Stefaniak, Formulation and stability of a novel artificial human sweat under conditions of storage and use. *Toxicol. Vitro* **24**, 1790–1796 (2010). <https://doi.org/10.1016/j.tiv.2010.06.016>